

Causal Analysis for Incident and Accident Investigation

(involving people and programmable systems)

Chris Johnson

University of Glasgow, Scotland.
<http://www.dcs.gla.ac.uk/~johnson>



**Glasgow Accident
Analysis Group**

June 2003




The Queen's Anniversary Prizes
for Higher and Further Education
1998

Rough Timings...

- 09.00-09.30 Overview
- 09.30-12.00 STAMP
 - 11.00-12.00 Group Session 1 (coffee @ 10.30)
- 12.00-13.30 Lunch
- 13.30-16.00 PARC
 - 15.00-16.00 Group Session 2 (tea @ 3)
- 16.00 End.

Part 1

- > 1. Overview
- 2. STAMP: System Theoretic Accident Modelling & Processes
- 3. PARCEL: Programmable Electronic Systems Analysis of Root Causes.
- 4. Wrap-up.



Determining System Inadequacy(ies) Responsible for Human Error




Figure 2-1. Determining system inadequacy(ies) responsible for human error

LEADER FAILURE

Code: 01

Key Word/Explanation: Inadequate/improper supervision by higher command.

Code: 02

Key Word/Explanation: Inadequate/improper supervision by staff officer.

Code: 03

Key Word/Explanation: Inadequate/improper supervision by unit command.

Code: 04

Key Word/Explanation: Inadequate/improper supervision by direct supervisor/missioned officer in charge/platoon leader/instructor. NOTE: Inadequate supervision becomes a root cause when it leads to accident-causing personnel mistakes or materiel failure/malfunctions. Inadequate supervision is more clearly identifiable at the immediate-supervisor level.

INDIVIDUAL FAILURE

Code: 15

Key Word/Explanation: Fear/Excitement/Anger (inadequate composure). Each person is a part of the system. Therefore, his state of mind is a system element. Inadequate composure is a temporary state of mind that becomes a root cause when a person makes an accident-causing error because of fear, excitement, or some related emotional factor made clear, rational thought impossible.

Code: 16

Key Word/Explanation: Overconfidence/complacency in abilities. Overconfidence is a temporary state of mind that becomes a root cause when an accident is caused by a person's unwarranted reliance on: his own ability to perform a task, the ability of someone else to perform a task, the performance capabilities of equipment or other materiel.

Code: 17

Key Word/Explanation: Lack of confidence. Lack of confidence is a

Table B-5

System: Inadequacies/Readiness Shortcomings/Root Causes—Continued

temporary of mind that becomes a root cause when an accident is caused by a person's unwarranted lack of reliance on: his own ability to perform the task, the ability of someone else to perform the task, the performance capabilities of equipment or other materiel.

Code: 18

Key Word/Explanation: Haste/Altitude (poor motivation). Haste/altitude (poor motivation) is a temporary state of mind that becomes a root cause when a person makes an accident-causing mistake because haste is in a hurry (haste), or has a poor/bad attitude.

Code: 19

Key Word/Explanation: Fatigue (self-induced). Fatigue is a temporary physical and/or mental state that becomes a root cause when a person makes an accident-causing error because of reduced physical or mental capabilities resulting from previous activity and/or lack of rest.

Code: 20

Key Word/Explanation: Effects of alcohol, drugs, illness. The temporary effects of alcohol, drugs, or illness become a root cause when a person makes an accident-causing error because of reduced physical or mental capabilities resulting from one or more of these effects.

Code: 21

Key Word/Explanation: Environment conditions. Unknown or unavoidable conditions, which result in materiel failure or induce human error.

Code: 97

Key Word/Explanation: Insufficient information to determine system inadequacy/cause.

OPERATIONAL EFFECT	IMMEDIATE EFFECT	EVENT TYPE	STATUS	Let	ATA	Loc	Dep	Dest	Desc	Cost	Del
Aircraft Unfit for Service	Abnormal Landing	Airport Management									
Air Turnback	Aircraft Systems Inhibited	ATM									
Delay	Airprox	Birdstrike									
Diversions	Altitude Deviation	Cabin Management									
Ambulance	Avoidance Manoeuvre	Documentation/Data									
Extra Security Checks	Damage Group Equipment/Vehicle	Environmental									
Maintenance Action Required	Damage to Aircraft	Flight Management									
Return to Stand	Damage to Other A/C	Maintenance									
Police Involved	EGPWS/GPWS - Hard Warning	Passenger									
Fire Services	EGPWS/GPWS - Soft Warning	Ramp Management									
Ferry Flight	Emergency Checklist	Security									
11/01/732	Emergency Declaration - Mayday	Weather									
3/01/732	Emergency Declaration - PAN	Air Cond + Pressn									
3/01/732	Emergency Descent	APU									
3/01/732	Emergency Evacuation	Autoflight									
7/01/732	Engine Operated at Low Power	Cabin Equipment									
3/01/732	Engine Shutdown	Communications Systems									
3/01/732	Fire Extinguisher System Activated	Doors									
4/01/732	Fuel Jettison	Electrics									
3/01/732	Fuel Spill	Engine									
2/01/732	Go-Around	Fire Protection									
1/01/732	Low Fuel State	Flight Controls									
3/28/00/732	Medical Procedure On-Board	Fuel									
3/29/00/732	Other Automatic Systems	Hydraulics									
3/27/00/732	Oxygen - Flying Crew	Ice/Rain Protection									
3/28/00/732	Oxygen - Passengers	Instruments									
3/28/00/732	Passenger Caution	Landing Gear									
3/24/00/732	Passenger Off-Loaded	Lights									
3/23/00/732	Portable Fire Extinguisher Discharged	Raw Equipment									
3/22/00/732	Rapid Disembarkation	Oxygen									
3/21/00/732	RAT Deployment	Pneumatics									
3/20/00/732	RTO - High Speed	Propellers									
3/19/00/732	RTO - Low Speed	Safety Equipment									
3/18/00/732	Smoke Detector Activated	Structures									
3/25/00/732	Stall/Alpha Protection	Water/Waste									
3/17/00/732	Standby Inst/Sys Use	Windows									
3/16/00/732	TCCAS RA										
1/02/732	Temporary Loss of Control										

Descriptor Selector

Descriptors	Summary	Notes	Keywords
Operational Effect	Immediate Effect	Event Type	Descriptors
Police Involved	Passenger Off-Loaded	Passenger	Abusive
Return to Stand			

Untitled Document - Microsoft Internet Explorer
 File Edit View Favorites Tools Help
 Back Search Favorites Media
 Address C:\Research\NPSA\erForm2(RCA)\rca index.htm
 Go

Home FAQ Toolkit Help Save now

Causal Factors

- Patient
- Equipment & Resources
- Education & Training
- Communication
- Working Conditions
- Team & Social
- Individual
- Task
- Strategy & Policy

Root Cause Analysis Form

This section of the e-form is dedicated to the identification of the positive and negative factors influencing the event you have described. The quality and quantity of information you share will enable the NPSA to better identify causal factors that need to be subject to deeper and more rigorous analysis in order to effect tangible improvements on a national scale. The taxonomy classification used in this form is based upon that developed by the Clinical Risk Unit at University College London.

Input ID ID search

Instructions for Completion

Please enter into the fields provided all of the problems (Care Management or otherwise), or issues of concern that you undertook a causal analysis of as part of your investigation into this event.

For each problem / issue of concern work through the highlighted taxonomies providing textual information about either the positive (or mitigating elements) of each influencing factor, or its negative influence on the course or outcome of the event being reported.

For each influencing factor use the radio buttons provided to indicated the level of impact that you think this factor had on either the course or outcome of the event.

If there are no influencing factors associated with a particular taxonomy click on the relevant button provided for this purpose and you will automatically be taken into the next taxonomy in the sequence.


Once all taxonomies have been visited you will be offered the opportunity to enter information on any other issue you undertook causal analysis on. Continue with this cycle until all relevant problems have been entered into the e-form

If, subsequent to an RCA having been performed, there are further developments including possible judicial recommendations, please enter the relevant details in the text area below:

Start Mail :: INBOX - Mi... Seamlil Hydro - Di... Risk Page - Micro... top - Microsoft In... rca index - Micro... Untitled Docum... eForm2(RCA) Microsoft PowerP... Acrobat Reader ... My Computer 9:32 AM

Milford Haven





Control system closes valve A, starves debutanizer.

Also closes valve B, heating raises debutanizer pressure.

Opens valve A, debutanizer flow restored.

Valve B should open to splitter.

Operators see misleading signals, valve B shown open.

Debutanizer fills while naptha splitter empties.

Motivation: Milford Haven



Separate displays.

Didn't check status of valve B, operators open valve C.

Debutanizer vents to flare, wet gas compressor restarts.

Should increase flow but increases debutanizer pressure.

Material vents to flare drum, corroded discharge breaks.

20 tonnes of hydrocarbon ignites, damage > £50 million.

Motivation: Milford Haven

- Human 'Error' and Plant Design/Operation

"The incident developed from the initial causative problems largely because of the combined effects of two factors. Firstly, operators were not provided with information systems configured to help them identify the root cause of such problems. Secondly, the preparation of shift operators and supervisors for dealing with a sustained upset and therefore stressful situation was inadequate.

- The alarm system was such that warnings of crucial problems were lost in the plethora of general and less important alarms... With alarms going off every two to three seconds, operators did not and could not react appropriately to each alarm."

Motivation: Milford Haven

- Safety Management Systems

"All of the key elements of the incident, and lessons drawn from it, have been seen and publicised before, in major accidents around the world. Those who are responsible for operating hazardous plants must have systems in place that bring to their attention these lessons of history.

The incident investigation demonstrated that some of the company's crucial safety management systems were not adequately performing their function. Examples are the systems for modification and inspection. The company was unaware of these defects in its safety management systems because its monitoring of their performance did not effectively highlight the problems."

Motivation: Milford Haven

- Risk Assessment

NB 3 years before the accident a modification was carried out so that automated high-capacity discharge pumps were no longer automatically started to move excess to slops when the flare discharge tank was full. Instead, low capacity pumps recycle material back to production process. Valves had to be operated manually if high-capacity pumping to slops was needed but this was seldom (never?) practiced.

"There should be a formal, controlled procedure for hazard identification and operability analysis for modifications (including emergency modifications) that ensures all safety issues identified at the design stage are reflected in how the modification is constructed and used..."

General Causal Analysis : Elicitation and Reconstruction

Barrier	Reason for failure?
Control loops link level in each vessel to discharge rate.	No control over input to vessel so assumes discharge rate can always exceed input rate. This was not the case during the incident.
	No secondary control loop to monitor input rate and limit it if this exceeded output. Hence there was no backup or secondary control system.
	Key sensors provided erroneous information to control system.
Control system displays linked to multiple level alarms.	Operators couldnt identify reason for alarms, especially valve B was closed, displays were grouped according to sub-processes hence it was difficult to gain over view of the system state.
	Operators were progressively overloaded with alarms. In the last eleven minutes they were expected to read and confirm 275 individual alarms, with similar high severity levels.

Prior/Ideal Condition	Present Condition	Effect of Change
All modifications that have safety implications should be considered by a formal hazard assessment.	The modification to the flare system that reduced the normal transfer capacity to storage tanks so that material could be recovered back to the production process was not considered in any formal safety assessment.	Assumed operators would manually restore system configuration so high-capacity pumps could remove excess materials from flare knockout drum. Operators unprepared to do this by lack of training and difficulty of diagnosing the state of their system.
Maintenance procedures should ensure that E/E/PES applications have accurate and timely information to meet control requirements.	After the incident 40 control loops tested. 24 required maintenance from minor mechanical damage to major faults. Only faulty debutanizer outlet valve (labeled B) occurred on the day of the incident. All of the rest were either known about or had not been detected for some time.	Maintenance issues created latent conditions for lightening strike to act as catalyst. Key readings confused operators. E/E/PES sensors downstream report valve B closed. However, flow indicator closest to valve indicated a flow and level in debutanizer that was below maximum even though full.



Environment

08.30: Electrical storm causes power disruptions

Alarm system

08.30: Visible & audible alarms as vacuum gas oil flow into FCCU falls below acceptable limit.

08.39: Debutanizer cascades alarm and closes output valve as level falls in debutanizer.

08.40+: Naptha splitter cascades alarm as level falls in supply from debutanizer.

Operators

08.33: Operators respond by manually reducing flow to deethaniser using computer panel in control room.

09.12: E/E/PES shows that debutanizer outlet valve (B) opened by flow indication and debutanizer level below maximum due to failed sensor .

Deethanizer

08.34: 'Temperamental' deethanizer valve closes completely

08.39: Deethanizer rapidly empties so E/E/PES responds by closing output to deethaniser.

09.13+: Liquids accumulate in deethaniser and downstream to debutaniser as valve B fails shut

Debutanizer


08.39: Debutanizer cascades alarm and closes its output valve as level falls in debutanizer.

08.46: Debutanizer pressure rises rapidly as it now contains vaporized materials that had been received from deethaniser



09.12: Debutanizer outlet valve (B) erroneously shown to have been opened by the E/E/PES as liquid levels are reestablished.

Flare system

08.47 Materials vent to flare system, some returned to process via recovery system.



Key



General Causal Analysis Techniques: Flow Charts

MORT


Sub-tree: Management LTA


Risk Assessment LTA	Hazard	Release of hydrocarbons into environment after leak from over-pressurized flare drum.
Hazard Analysis LTA	Control operability problems	People and systems in the plant and the wider environment... No risk assessment of change to emergency pumping system; now requires operator intervention to reconfigure flow from retrieval to evacuation...

MORT (Stage 2) Analysis Form

PRISMA

- Anaesthesia study:
 - 15 incidents:
 - 78 root causes (5.2 ave);
 - 27% organisational causes;
 - 40% (direct) human causes;
 - 26% technical causes.
- A&E study:
 - 19 incidents:
 - 93 root causes (4.9 ave);
 - 45% organisational causes;
 - 41% (direct) human causes.





Example PRISMA Classification/Action Matrix


	External Factors (O-EX)	Knowledge Transfer (OK)	Operating procedures (OP) &	Manag. priorities (OM)	Culture (OC)
Inter-departmental communication	X				
Training and coaching		X			
Procedures and protocols			X		
Bottom-up communication				X	
Maximise reflexivity					X

General Causal Analysis Techniques: Accident Models

TRIPOD

- General Failure Types:
 - Hardware
 - Maintenance management.
 - Design.
 - Operating procedures.
 - Error-enforcing conditions.
 - Housekeeping
 - Incompatible goals
 - Communication
 - Organisation
 - Training
 - Defence planning

Failed barriers or defences



Control logic fails to prevent build of hydrocarbons in the flare system.

Operator intervention fails to diagnose the source of warnings once anomalies detected.

Target: People and systems in the plant and the wider environment...

Active Failure: Valve B sticks at shut even though commanded to open.

Active Failure: Operators fail to diagnose valve B block even though plant was well equipped with level alarms.

Precondition: Monitoring only on outflow, underlying logic assumes discharge rate will always increase to cope with increased input into section.

Precondition: No second control loop to reduce the inflow if material accumulates in any stage of the process.

Precondition: Undiagnosed blockage would cause inflow to exceed outflow.

Precondition: Displays on output from process distributed amongst five product streams.

Precondition: No process overview with trend information over a suitable time period.

Latent Failure: failure to adequately perform hazard assessment.

Failure types:
3. Design
4. Operating procedures

Latent Failure: failure to design for defence in depth by focussing on single control loop.

Failure types:
3. Design
11. Defence planning

Latent Failure: failure to monitor other similar incidents in units related to this one.

Failure types:
8. Communication
9. Organisation
11. Defence planning


Latent Failure: failure to design/configure displays for abnormal process.


Failure types:
3. Design
4. Operating procedures.
5. Error enforcing conditions

Latent Failure: failure to train using displays available for abnormal process.

Failure types:
5. Error enforcing conditions
10. Training.


General Causal Analysis Techniques: Argumentation Techniques







Part 2


1. Overview.
- > 2. STAMP
3. PARCEL.
4. Wrap-up.






HAUSE







Back to Milford Haven











Control Flaws


- **1. Inadequate Enforcements of Constraints (Control Actions)**
 - 1.1 Unidentified hazards
 - 1.2 Inappropriate, ineffective or missing control actions for identified hazards
 - 1.2.1 Design of control algorithm (process) does not enforce constraints
 - Flaws in creation process
 - Process changes without appropriate change in control algorithm (asynchronous evolution)
 - Incorrect modification or adaptation.
 - 1.2.2 Process models inconsistent, incomplete or incorrect (lack of linkup)
 - Flaws in creation process
 - Flaws in updating process (asynchronous evolution)
 - Time lags and measurement inaccuracies not accounted for
 - 1.2.3 Inadequate coordination among controllers and decision makers
- **2 Inadequate Execution of Control Action**
 - 2.1 Communication flaw
 - 2.2 Inadequate actuator operation
 - 2.3 Time lag
- **3 Inadequate or Missing Feedback**
 - 3.1 Not provided in system design
 - 3.2 Communication flow
 - 3.3 Time lag
 - 3.4 Inadequate sensor operation (incorrect or no information provided)



Control Relationship	Constraint violation	Justification
[Operator-> Control System]	1.2 Inappropriate, ineffective or missing control action for identified hazard	Operator failed to check valve B and instead opened valve C - repeatedly forcing hydrocarbons into the flare system.
[Control System -> Operator]	3.4 Inadequate sensor operation	System failed to show correct state of valve B.
	3.2 Communication flow	System failed to provide necessary process overview.




Control Relationship	Constraint violation	Justification
[Valve A-> debutaniser-> Valve B]	1.2.1 Design of control process does not enforce constraints- flaws in creation process	Assumption that outflow from debutanizer via valve B will always be capable of exceeding the inflow via valve A.



Control Relationship	Constraint violation	Justification
[Offsite managers-> Site managers-> Operators]	1.1 Process models inconsistent, incomplete or incorrect (lack of linkup)	Failure to realize that additional operator training and simulations would be required to prepare change over from reclamation configuration to initiation of high-capacity discharge pumps.
[Regulators <-> Offsite managers]	1.1 Unidentified hazards	Failure to assess hazards associated with build-up of material in the flare drum without starting discharge pumps.

Concerns 1: Responsibility

- Senior Management controls everything??



- How to represent their impact on design??

Concerns 2: Success or Failure?

- Organisational structures always look bad:
 - What does successful organisation look like?
 - Informal, messy, complex - flexible?
 - Milford Haven managers 'help out' operators.
- Also, pressure to simplify control models.

Concerns 3: Omissions?

- How do we represent missing controls?
 - Inadequate risk assessment on flare modification.
- How do we represent missing entities?
 - No review board for operation post flare modification.
- Also, pressure to simplify control models.


	Analyst 1	Analyst 2
1 Inadequate Enforcement of Constraints		
1.1 Unidentified hazards	Factor 2: "Failure to perform risk analysis of a modified procedure... •Factor 4: "Failure to properly respect autonomous Safe Mode triggers	Factor 2: Failure to perform risk analysis of a modified procedure set. Factor 7: Failure to recognise risk posed by operations team overload Factor 6: Failure to Question Telemetry discrepancies
1.2 Inappropriate, ineffective or missing control actions for identified hazards		
1.2.1 Design of control algorithm does not enforce constraints	Factor 1: Flight operations team modified flight-demonstrated ground operations procedures as a part of the ISTP Ground System re-engineering... Factor 10: Over reliance of flight operations team on ESA and MMS representatives...	
1.2.2 Process model inconsistent, incomplete or inaccurate	Factor 6: Failure to Question Telemetry discrepancies Factor 9: Emphasis on science return at expense of spacecraft safety Factor 13: Failure to validate the planned sequence of events in advance.	Factor 1: Flight operations team modified flight-demonstrated ground operations procedures as a part of the ISTP Ground System re-engineering... Factor 9: Emphasis on science return at expense of spacecraft safety
1.2.3 Inadequate coordination among controllers and decision makers	Factor 7: Failure to recognise risk posed by operations team overload Factor 8: Failure to recognise shortcomings in implementation of ESA/NASA agreements...	Factor 10: Over reliance of flight operations team on ESA and MMS representatives...
2 Inadequate Execution of Control Actions		
2.1 Communication flaw		Factor 5: Failure to follow the operations script; failure to evaluate primary and ancillary data...
2.2 Inadequate actuator operation	Factor 5: Failure to follow the operations script; failure to evaluate primary and ancillary data... Factor 11: Dillution of observatory engineering support... Factor 12: Failure to resolve a critical deficiency report in a timely manner	Factor 12: Failure to resolve a critical deficiency report in a timely manner Factor 4: Failure to properly respect autonomous Safe Mode triggers
2.3 Time lag		
3. Inadequate or Missing Feedback		
3.1 Not provided in system design		Factor 13: Failure to validate the planned sequence of events in advance.
3.2 Communication flaw	Factor 3: Failure to communicate change	Factor 3: Failure to communicate change
3.3 Time lag		
3.4 Inadequate sensor operation		Factor 8: Failure to recognise shortcomings in implementation of ESA/NASA agreements... Factor 11: Dillution of observatory engineering support...


Part 3

1. Overview.
2. STAMP
- > 3. PARCEL
4. Wrap-up.

	Elicitation and Analysis techniques		Event Based Techniques		Flowcharts and taxonomies		Accident Models			Argumentation Techniques	
	Barrier Anal.	Change Anal.	Timelines	Accident Fault Trees	MORT	PRISMA	TRIPOD	STAMP	WBA	CAE	
IEC 61508 Lifecycle phase											
Concept	F	F	U	U	F	P	F	P	U	F	F
Scope	F	F	U	U	F	P	F	P	U	F	F
Risk Assessment	P	P	P	P	F	P	P	F	U	F	F
Safety Requirement	F	F	U	U	P	P	F	F	U	F	F
Allocation	F	P	P	U	P	P	F	P	U	U	U
Planning of Validation, Operation & maintenance	U	P	P	P	F	F	U	P	P	P	U
Realisation	U	F	F	P	U	P	U	F	F	F	U
Installation / Commission	U	P	F	P	P	P	P	P	F	F	P
Validation	P	P	F	P	P	P	P	U	F	F	P
Operation & Maintenance	P	F	F	P	P	P	F	F	F	F	P
Modification	U	F	F	P	P	P	U	F	F	F	P
IEC 61508 Common Requirements											
Competency	P	P	P	P	P	P	F	P	P	P	P
Lifecycle	U	P	P	P	P	P	P	P	P	P	P
Verification	P	P	P	P	P	F	P	P	P	P	P
Safety management	P	P	P	P	P	P	P	P	P	P	P
Document.	P	P	P	P	P	P	P	P	P	P	P
Functional safety assessment	P	P	P	P	P	P	P	P	P	P	P


Key: (U)nsupported, (P)artially supported, (F)ully supported





IEC 61508 common requirements	
Competency	<ol style="list-style-type: none"> 1. LTA operations competency 2. LTA maintenance competency 3. LTA modification competency
Lifecycle	<ol style="list-style-type: none"> 1. LTA definition of operations accountabilities 2. LTA definition of maintenance accountabilities 3. LTA definition of modification accountabilities
Verification	<ol style="list-style-type: none"> 1. LTA verification of operations 2. LTA verification of maintenance 3. LTA verification of modification
Safety management	<ol style="list-style-type: none"> 1. LTA safety culture 2. LTA safety audits 3. LTA management of suppliers
Documentation	<ol style="list-style-type: none"> 1. documentation unclear or ambiguous 2. documentation incomplete 3. documentation not up to date
Functional safety assessment	<ol style="list-style-type: none"> 1. LTA O & M assessment 2. modification assessment LTA 3. assessment incomplete 4. insufficient skills or independence in assessment team

Key: LTA is Less Than Adequate, IEC 61508 references are to Part 1 except as indicated by parentheses e.g. (2)




Would the incident have been prevented if:					
Hazard and Risk Assessment	- hazard and risk analysis had considered all modes of operation and causes	- hazard and risk analysis had considered all modes of operation and causes	- hazard and risk analysis had considered all modes of operation and causes	- hazard and risk analysis had considered all modes of operation and causes	- hazard and risk analysis had considered all modes of operation and causes
Design	- different equipment selected? - installation design different? - configuration was correct?	- maintenance facilities had been designed adequately - the maintenance facilities had been installed according to design	- operations facilities had been designed correctly - the operations facilities had been installed according to design	- different equipment selected? - installation design had been different? - configuration was correct?	- different equipment selected? - the installation design had been different? - configuration was correct?
Installation & Commission	- the equipment had been installed according to design	- the maintenance facilities had been installed according to design	- the operations facilities had been installed according to design	- the equipment had been installed according to design	- the equipment had been installed according to design
Validation	- the setting had been checked during validation	- maintenance facilities had been fully checked	- operations facilities had been fully checked	- equipment condition had been fully checked	- equipment condition had been fully checked
Operation & Maintenance	- maintenance procedures were applied - maintenance procedures were improved - maintenance tools better - test interval was reduced	- correct maintenance procedure had been used - maintenance procedure was improved - permit procedures better	- correct operation procedure was used - operation procedure was improved - permit procedures improved	- maintenance procedures were improved - maintenance proc. better - test interval was reduced - additional protection provided	- maintenance procedures were improved - maintenance tools improved - test interval was reduced - additional protection provided
Modification	- setting had been reviewed during impact analysis	- maintenance facilities or procedures had been reviewed during impact analysis	- operation facilities or procedures had been reviewed during impact analysis	- equipment used or installation design has been reviewed during impact analysis	- equipment used or installation design has been reviewed during impact analysis

Would the incident have been prevented if:			
Verification	- safety culture was improved - audits were more frequent	- safety culture was improved - audits were more frequent	- safety culture was improved - audits were more frequent
Lifecycle	- responsibilities were defined better - modification lifecycle was better defined	- a better verification scheme had been in place - a better verification scheme had been in place	- documentation was clear and sufficient - documentation updated
Competency	- operation or maintenance staff were more competent - modification carried out by more competent staff	- a better verification scheme had been in place	- documentation updated
Safety management	- safety culture was improved - audits were more frequent	- safety culture was improved - audits were more frequent	- safety culture was improved - audits were more frequent

Continued ...


Continued from previous figure





Would the incident have been prevented if:

	Competency	Lifecycle	Verification	Safety management	Documentation	Safety assessment
Operation & Maintenance	- operation or maintenance staff were more competent	- responsibilities were defined better	- a better verification scheme had been in place	- safety culture was improved - audits were more frequent	- documentation was clear and sufficient	- assessment had been carried out on O&M phase
Modification	- modification had been carried out by more competent staff	- modification lifecycle was better defined	- a better verification scheme had been in place	- accountabilities were better defined - suppliers not reviewed	- documentation had been updated	- assessment had been carried out on modification

Causal Event	IEC 61508 Classification	Route through flow chart	Rationale
Decision to open valve C.	Validation	<p>Incorrect action taken by system or operator-></p> <p>Operator fails to mitigate hazard -></p> <p>Accident would have been avoided if operator facilities had been fully checked.</p>	<p>The operators intervened in the automated control system to open valve C this time led the compressor to trip and forced excess fluid into the flare system. The poorly designed displays prevented them from diagnosing the source of the increased pressure in the debutanizer and the potential hazard from their actions in opening C. Improved display design might have occurred if they had been validated against a wider range of operational scenarios.</p>
Failure to open valve B.	Operation and maintenance	<p>System fails to take required action -></p> <p>Failure caused by maintenance -></p> <p>Accident would have been avoided if maintenance procedure were improved.</p>	<p>The computer control system was designed to automatically open valve B when flow was restored to the debutanizer. This command failed. Subsequent investigation found of 39 instrument loops 24 needed attention ranging from minor mechanical damage to major maintenance faults.</p>







Causal Event	Associated Conditions	IEC 61508 Lifecycle Classification	Justification	IEC 61508 Common Requirements Violation	Justification
Liquid forced from full flare drum to drum to corroded discharge pipe.	Modification to flare drum pump prevents excess being pumped to storage tanks.	<p>Modification:</p> <p>1 impact analysis incorrect.</p>	After modification in normal operation automated pumps would now reclaim materials from the flare. Manual intervention was required to restore high velocity pumping to slops under 'emergency' conditions. Operators did not intervene in this manner and the impact of this was not considered.	<p>Functional Safety Assessment:</p> <p>2. Modification assessment LTA.</p>	Assessment of the modification had identified the need to override low capacity transfer of materials in flare but had not considered what would happen if manual intervention did not occur.
	Operators fail to attend to high-level alarm for flare drum during 25 minutes prior to explosion.	<p>Modification:</p> <p>4 LTA verification and validation</p>	Inadequate testing to see if operators would intervene once switch was made away from automated default use of high velocity pumps to slops.	<p>Verification:</p> <p>3 LTA verification of modification</p>	There appears not to have been any verification to determine whether operators could or would intervene to perform the necessary manual reconfiguration that was necessary to start high velocity pump transfer to storage tanks from the flume tank.
	Maintenance failure leaves sensor indicating that the flow and level in the debutanizer was believed to give erroneous indication below maximum.	<p>Operation and maintenance:</p> <p>9 LTA procedures to monitor system performance</p>	Operators were presented with deluge of automated alarms and lacked technical/procedural support to discriminate high priority alarms.	<p>Functional Safety Assessment:</p> <p>1. LTA Operations and Maintenance assessment.</p>	The incident was caused by a number of problems in the way in which the system was both maintained and operated. Maintenance failures meant that automated systems and operators could not rely on some sensor readings. The tight integration of heat transfer operations together with poor alarm handling created immense burdens for system operators under abnormal situations and these demands appear not to have been assessed in a systematic manner.
Operators open valve C	Maintenance failure leaves sensor indicating that the flow and level in the debutanizer was believed to give erroneous indication below maximum.	<p>Operation and maintenance:</p> <p>2: maintenance procedures need improvement</p>	The programmable systems and operator alarms depended on accurate sensor information. Inadequate maintenance created systemic vulnerabilities that were likely to lead to mishaps.	<p>Safety management:</p> <p>2. LTA Safety Audits</p>	
	Display presents plethora of alarms that prevent operators from checking status of valve B.	<p>Allocation:</p> <p>4. Installation design</p>	Operators had to acknowledge almost 400 alarms in the last 12 minutes of the mishap. This took away from time to diagnose the problem and plan their intervention.		
Operator preoccupied by controlling heat transfer process between components		<p>Overall safety requirements:</p> <p>4. Installation design.</p>	Heat generated as a by-product of one sub-process was used elsewhere in the system rather than dissipated by cooling systems. This created delicate dependencies that would be disturbed and impose additional burdens on operators during emergency situations.		

Causal Event	Associated Conditions	IEC 61508 Lifecycle Class.	IEC 61508 Common Requirements Violation	Recommendation	Priority	Responsible authority	Deadline for response	Date Accepted/Rejected
Liquid forced from full flare drum to corroded discharge pipe.	Modification to flare drum pump prevents excess being pumped to storage tanks.	Modification: 1 impact analysis incorrect	Functional Safety Assessment: 2. Modification assessment LTA Verification: 3. LTA verification of modification	1. Flare system must be redesigned to provide effective removal of slops from knock-out drum at adequate rate to prevent overflowing. 2. There should be a formal controlled procedure for hazard identification following all modification proposals. 3. Control and protection systems should be independent, particularly where they involve programmable systems. 4. Display systems to be redesigned to provide clearer indication of source of flow problems. Greater prioritisation of alarms will assist in this (see rec 7).	High	Production engineering team manager	1/4/2003	Accepted 15/2/2003
	Operators fail to attend to high-level alarm for flare drum during 25 minutes prior to explosion.	Modification: 4 LTA verification and validation Operation and Maintenance: 9. LTA procedures to monitor system performance.	Functional Safety Assessment: 1. LTA Operations and Maintenance assessment Safety management: 2. LTA Safety Audits		High	Plant safety manager	1/6/2003	Accepted 15/2/2003
	Maintenance failure leaves sensor indicating that the flow and level in the debutanizer was believed to give erroneous indication below maximum.	Operations and maintenance: 2. maintenance procedures need improvement.		5. Safety management system to record and review incident information from other similar plants, causes of mishap already well documented. 6. Safety management system to include monitoring of its own performance – for instance over assessment of modifications.	Medium	Plant safety manager	1/5/2003	Accepted 15/2/2003
	Operators open valve C	Display presents plethora of alarms that prevent operators from checking the status of valve B. Operators preoccupied controlling heat transfers process between components.	Allocation: 4. installation design. Overall safety requirements: 4. installation design.	7. Training of staff will focus on high-stress situations as well as production critical issues. (see also recommendation 4)	Medium	Plant safety manager	1/5/2003	

Concerns 1:Flow Chart Validation

- The flow chart is very simplistic.
- Will people be able to use it consistently?
- How much must we change for each industry?
- Can it really be used by:
 - developers, vendors, integrators and end-users?

Concerns 2: Human Factors

- PARCEL is narrowly based on IEC61508.
- IEC61508 is poor on human factors issues.

Operation & Maintenance	<ul style="list-style-type: none"> - operation procedures were applied <ul style="list-style-type: none"> - operation procedures were improved 	<ul style="list-style-type: none"> - correct maintenance procedure had been used - maintenance procedure was improved - proof testing was more frequent 	<ul style="list-style-type: none"> - correct operation procedure was used - operation procedure was improved - permit procedures were improved 	<ul style="list-style-type: none"> - mitigation procedures were applied - mitigation procedures were improved - mitigation system was proof checked more frequently 	<ul style="list-style-type: none"> - operation procedures had been applied - operation facilities or procedures were improved
-------------------------	---	--	---	--	---


- But HSE and others are addressing this?

Concerns 3: IEC61508?

- PARCEL embodies IEC61508:
 - Can we use it with other standards?
 - Will it really help spot problems in 61508?
- PARCEL embodies flowcharts and ECF:
 - We could use flowcharts and STAMP?
 - Must match tool complexity to industry need.

Part 4

1. Coffee and overview.
2. STAMP
3. PARCEL
- > 4. Wrap-up.





So what happens in practice?

	World War II (1942-1945)	Korea (1950-1953)	Vietnam (1965-1972)	Desert Storm and Desert Shield (1990-1991)
Accidents	56%	44%	54%	75%
Friendly Fire	1%	1%	1%	5%
Enemy Actions	43%	55%	45%	20%

Percentage of all accounted casualties, fatal and non-fatal (US Army, Risk Management Field Manual 100-14)

Decision Making and Scale

- 8+ revisions of US M9 Armored Combat Earthmover manuals in a single month in 2000:
 - TM5-2350-262-10, TM5-2350-262-10HR, LO5-2350-262-12, TM5-2350-262-20-1 & 2,
 - TM5-2350-262-20-3, TM5-2350-262-34, TM5-2350-262-24P, TM5-2815-240-34 & P.
- Problems of scale and complexity require carefully designed reporting processes.
- The US Army's (2000) Accident Investigation and Reporting Procedures Handbook
 - Department of Army 60 days to inform Army Safety Center of corrective actions.
 - Interim and follow-up reports required every 90 days until the actions are closed.



Limitation 1: Technological Change



- M939A2 'fish-tailed' on a steep hill:
 - Weather, road conditions good;
 - Trailer tires blew and truck rolls off road;
 - Tires well-maintained, no defects;
 - Witnesses state vehicle under speed limit.
- Any Safety-of-Use-Messages or Ground Precautionary Messages?
 - Unit personnel said no, M939A2s only recently replace older models;
 - Investigation board checks Army Electronic Product Support Bulletin Board;
 - 2 safety messages limit M939A2 to 45mph until antilock brakes & radials fitted;
 - When maintenance received messages they didn't have any M939A2 trucks...


Limitation 2: Organisational Change

- The US Army's Modification Work Order (MWO) program:
 - ensure 'identified operational and safety problems' consistently implemented across US Army
 - centralized database records progress of maintenance recommendations.
 - Army Headquarters & Materiel Command query if units meet timescales in safety notices.
- Database discontinued following a structural reorganization in 1990:
 - Control over modification funding transferred from HQ;
 - Control given to program sponsors
 - Weapon systems, eg M1A1 tank, or product support centres, eg Squad Automatic Weapon.
- 'Army headquarters and Materiel Command officials don't have adequate overview of equipment modifications across the force, funding requirements, logistical support requirements and information for deployment decisions' (US Army Safety Center, 2001).

Limitation 3: Organizational Complexity



- Soldier falls during 'inverted' rope descent.
- Previous incidents led to US Army FM21-20:
 - include platform at top and safety net.
 - use Corps of Engineers drawing 28-13-95.
 - diagram didnt include safety net or platform!!



'Confusion exists concerning the proper design and construction of this obstacle'

Limitation 4: Safety Culture

National Defence Authorization Act:

- develop Ranger 'safety cells';
- must know geographic training area (weather etc.);
- But Act doesn't give detailed guidance.



General Accounting Office report:

- "no change from safety oversight" at time of incidents;
- focus on "checklists of procedures";
- "whether files of safety regulations and risk assessments are maintained"
- Do not monitor effectiveness of incident recommendations.

Limitation 5: Risk Analysis

- Canadian Engineering Officer hurt when fragment shatters bunker viewport:
 - 4-ply laminate glass design 100 kg of TNT at 130M with less than 2% glass loss;
 - Glazing performed as designed, 2% glass lost in the eye of a student.

Recommendations:

- sacrificial polycarbonate can be replaced if damaged, final protection for viewers;
 - Or plentiful supply of "offset viewblock" NSN 6650-12-171-9741 tank periscope.
- But sacrificial layers increase glass thickness and so use video?

Limitation 6: Inherent Risk

- Never under-estimate organizational complexity of human 'error' ...
- "Many units stated first aid training packages lack realism. IV and morphine training were essential... During 6 months in theatre, no soldier gave artificial respiration, treated a fracture or did Heimlich manoeuvre. Treated 17 bullet-wounds, 3 shrapnel-wounds and 7 minefield cases.

As threat level dropped for latter rotations, comments on need for IV and morphine training waned. All unit medical staff strongly recommend that it not be completed because of inherent dangers in administering IVs or morphine..."


(Canadian Army's Lessons Learned Centre, NATO Implementation & Stabilization Force in Bosnia-Herzegovina. 1999)

- Balancing operational need and medical caution?





Temperature Chart and Digital Display
 The round window in the aluminum box contained the temperature chart. The rectangular cutout above and to the left of the chart contained the digital temperature readout.



Any Questions?

